

**Water Quality Report  
2009**

**Three Rivers Filtration Plant  
Fort Wayne City Utilities  
Fort Wayne, IN**



*Our mission:*

*“To provide our customers with an adequate supply of water that meets all state and federal drinking water regulations at a fair price.”*

**Three Rivers Filtration Plant  
1100 Griswold Drive  
Fort Wayne, IN 46805-4100**

## **Three Rivers Filtration Plant Fort Wayne, IN**

### **History:**

The Three Rivers Filtration Plant was erected in 1933 with a capacity of 24 million gallons of drinking water per day. This capacity was increased to 48 million gallons per day in 1955, and further increased in 1979 to 72 million gallons per day. Today the facility produces an average of 30 million gallons of drinking water each day. Surface water from the St. Joseph River is pumped from the Saint Joseph reservoir to the Filtration Plant located 2.5 miles south of the reservoir. The storage capacity of the North Anthony reservoir is about 250 million gallons. Additional reservoir storage for the Fort Wayne water supply is located in the Saint Joseph River above Cedarville Dam, and at the Hurshtown reservoir. The Cedarville Dam holds approximately 550 million gallons of raw water while the Hurshtown reservoir holds approximately 1.8 billion gallons of raw water. During periods of severe drought, water from the upstream reservoirs can be released into the river to ensure that the Filtration Plant has an adequate supply of raw water for an extended period of time.

### **Source of water:**

The quality of the raw water from the Saint Joseph River is extremely variable due to rapid changes that occur during runoffs. Runoffs occur when saturated soil can no longer absorb excessive rain or melting snow. Consequently, the rain or melting snow runs off into the river carrying with it dirt, sticks, pesticides and other debris. Water conditions are monitored constantly so that the treatment process produces water that is compliant with drinking water regulations as well as consistent in quality, taste and odor.

### **Treatment Process:**

Our treatment process utilizes lime to soften water, iron sulfate to coagulate suspended solids, disinfectants to control pathogens and other microorganisms, carbon dioxide to adjust pH, and powdered activated carbon for pesticide removal and taste and odor control. In addition, fluoride is added to our finished water in small amounts to help reduce tooth decay. After chemical treatment and clarification, water is filtered to remove fine particles and microorganisms.

### **Testing:**

With the use of on-line analyzers, samples are monitored continuously at every stage of the treatment process. This ensures that the proper amounts of chemicals are added to produce high quality finished water.

In the analytical lab, chemists sample finished water to test for several inorganic parameters. Additional samples are collected and sent to private labs to test for metals, dis-infection by-products, volatile organic compounds, synthetic organic compounds and pesticides. Finished and raw water samples are also collected to test for cryptosporidium and

## **Three Rivers Filtration Plant Fort Wayne, IN**

giardia. In all, over 120 different contaminants are monitored, logged and reported to various state and federal regulatory agencies.

Representative samples of the distribution system are tested daily for disinfectant residual, absence of Coliform, and absence of E. Coli. Approximately forty random samples are collected and tested each week for this purpose. Additionally, in 2009, 51 samples were collected from the distribution system to test for lead and copper. Currently, Fort Wayne water meets the standards for lead and copper. Additional lead and copper testing will be required in the future.

### **Extra Initiatives:**

A great number of factors, both internal and external, affect the quality of water that is produced at the Three Rivers Filtration Plant. While many of these factors are outside the control of operating personnel, we realize that our ultimate goal must be to strive for continuous improvement of water quality as a whole. Consequently, we are participating in programs to address issues that impact raw water quality. These programs also utilize innovative technology to measure the amount of pathogens and pesticides in both raw and finished water.

In order to address issues affecting the raw water quality, we are participating in the Saint Joseph River Watershed Initiative. The Watershed initiative consists of a group of stakeholders from the six counties in Indiana, Ohio and Michigan that influence the quality of the Saint Joseph River. The initiative has a monitoring program in place that collects samples from various points in the watershed. These samples are analyzed in our lab for pesticides and pathogens. One particular pesticide called atrazine is very common in Northern Indiana. The EPA standard only requires that we monitor quarterly for atrazine in drinking water. However, the filtration plant has opted to monitor atrazine in drinking water on a daily basis during the time period that the river is susceptible to excessive levels of atrazine.

The Filtration Plant currently utilizes powdered activated carbon to reduce atrazine in finished water to its lifetime maximum contaminant level. It is important to note that activated carbon can remove most of the pesticides found in raw water, however, it is unable to remove all of the pesticides especially when source water pesticide levels are elevated. In 2009 there were only twelve days when the atrazine levels of finished water exceeded the MCL of 3.0 mg/L.

The Three Rivers Filtration Plant has voluntarily joined with over 300 United States water utilities of similar size, along with the American Water Works Association and the United States Environmental Protection Agency in a Partnership for Safe Water. This program involves a comprehensive plant specific look at treatment processes and water quality assessment to optimize water quality. Fort Wayne has completed three of four phases of this partnership and has maintained phase three certification for the past ten years.

## Three Rivers Filtration Plant Fort Wayne, IN

### System Highlight:

Annual Production	10.82 Billion Gallons
Population Served (approximate)	250,000
Metered Customers (active)	84,699
Distribution System	1152.2 miles
Number of Plant Employees	39
Number of Fire Hydrants	9089
Number of Valves	12,106

### Legend for Charts

MCL – Maximum Contaminant Level

CFU – Colony Forming Units

NTU – Nephelometric Turbidity Unit

ppm – Parts per Million (Milligrams per Liter)

ppb – Parts per Billion (Micrograms per Liter)

umho/cm – Micromhos per Centimeter

Note: Milligrams and Micrograms per Liter are expressed in terms of specific gravity of water.

## Three Rivers Filtration Plant Fort Wayne, IN

Three Rivers Filtration Plant

General Purification Summary

2009

	Raw Million Gallons	Raw Million Liters	Filtered Million Gallons	HSD Million Gallons
Plant # 1	4,595.31	17,393.26	3,384.96	
Plant # 2	4,576.76	17,323.02	3,891.21	
Plant # 3	2,521.00	9,541.99	3,538.94	
Million Gallons Total	11,693.07		10,815.11	10,203.68
Million Liters Total		44,258.27	40,935.20	38,620.93

<u>Chemical Application</u>	<u>Total pounds</u>	<u>Pounds per MG</u>	<u>PPM</u>	<u>GPG</u>
Lime to Raw	16,941,336.00	1,449	173.43	10.14
Ferric Sulfate to Raw	3,086,333.39	264	31.59	1.85
Liquid Carbon Dioxide	2,765,360.00	236	28.31	1.66
Carbon to Raw	417,603.00	36	4.27	0.25
Sodium Chlorite	509,608.25	47	5.64	0.33
Fluoride to Filter	376,564.92	35	4.17	0.24
Ammonia to Filter	26,882.10	2	0.30	0.02
Chlorine ro Generox	145,303.85	12	1.49	0.09
Chlorine to Chloramine	40,457.36	4	0.45	0.03
Total Chlorine	185,761.21	16	1.94	0.11

<u>Chemical Cost</u>	<u>Total \$</u>	<u>Per MG Filtered</u>	<u>% of Total</u>
Lime to Raw	\$ 1,185,893.52	\$ 109.65	47.34%
Ferric Sulfate to Raw	\$ 556,465.91	\$ 51.45	22.21%
Liq. Carbon Dioxide	\$ 92,878.38	\$ 8.59	3.71%
Carbon to Raw	\$ 238,117.43	\$ 22.02	9.50%
Sodium Chlorite	\$ 240,535.09	\$ 22.24	9.60%
Fluoride to Filter	\$ 116,416.07	\$ 10.76	4.65%
Ammonia to Filter	\$ 20,161.57	\$ 1.86	0.80%
Chlorine	\$ 54,785.64	\$ 5.07	2.19%
Total Chemical Cost	\$ 2,505,253.61	\$ 231.64	100.00%

### Filter Operation

Average Runs, Hour	94.17
Numbers of Runs Completed	2,286.38
Number of Filters Washed	2,300.13
Wash Water, Gallons	460,025,000.00
Average Gallons per wash	200,000.00
% Wash Water	4.25%

<u>Recarbonation</u>	<u>Liquid CO(2) Plant # 1</u>	<u>Liquid CO(2) Plant # 2</u>	<u>Liquid CO(2) Plant # 3</u>
	-	-	-
Total Pounds of CO(2)	1114901.6	1041472.4	608986.0
Pounds CO(2) Per Fuel Unit	0.1145	0.1145	0.1145
Pounds CO(2) Per MG	243	228	242
Primary Settled, OH-	40	40	36
Secondary Settled, HCO(3)-	28	30	21
Total Recarbonation	68.14	70.42	56.53
CO(2) Per MG Per PPM	3.56	3.23	4.27

## Three Rivers Filtration Plant Fort Wayne, IN

Draft of Operational Cost and Service Report for:

2009

Three Rivers Filtration Plant

<u>Chemical</u>	<u>Used</u>		<u>Unit Cost</u>		<u>Usage</u>	<u>Balance On Hand</u>		
Lime	8,471	TON @	\$ 140.00	/TON	= \$ 1,185,893.52	Lime	\$	125,767.60
Ferric Sulfate	3,086,333	LBS @	\$ 0.180	/LBS	= \$ 556,465.91	Ferric Sulfate	\$	36,056.37
Carbon	209	TON @	\$ 1,140.43	/TON	= \$ 238,117.43	Carbon	\$	28,516.17
Sodium Chlorite	5,096	CWT @	\$ 47.20	/CWT	= \$ 240,535.09	Sodium Chlorite	\$	34,755.44
Fluoride	188	TON @	\$ 618.62	/TON	= \$ 116,416.07	Fluoride	\$	14,312.56
Chlorine	2,810	CWT @	\$ 19.50	/CWT	= \$ 54,785.64	Chlorine	\$	2,765.10
Ammonia	269	CWT @	\$ 75.00	/CWT	= \$ 20,161.57	Ammonia	\$	2,377.86
Liq. Carbon Dioxide	1,383	TON @	\$ 67.17	/TON	= \$ 92,878.38	Liq. Carbon Dioxide	\$	1,679.75
<b>Total Chemical Cost=</b>						<b>\$ 2,505,253.61</b>		
							<b>Total</b>	<b>\$ 246,230.84</b>

Natural Gas Usage

Filtration Plant	285,431	CCF =	\$ 320,541.54
St. Joe Dam	9,388	CCF =	\$ 11,985.74
Northwest Station	2,289	CCF =	\$ 2,380.11
East Side Station	2,202	CCF =	\$ 2,816.11
Southwest Station	4,146	CCF =	\$ 5,120.73
West Side Booster	2,023	CCF =	\$ 2,672.10
Miscellaneous	-	CCF =	\$ -
<b>Total Natural Gas Usage</b>	<b>305,479</b>	<b>Natural Gas Cost</b>	<b>\$ 345,516.33</b>

Electric Power Usage

Filtration Plant	10,785,489	KWH Used =	\$ 584,769.71
St. Joe Dam	2,435,678	KWH Used =	\$ 139,002.28
Hurshstown	56,832	KWH Used =	\$ 4,544.15
Cedarville Dam	17,920	KWH Used =	\$ 1,538.51
West Side	168,371	KWH Used =	\$ 10,447.80
Northwest Station	1,164,736	KWH Used =	\$ 71,622.29
Southwest Station	281,490	KWH Used =	\$ 17,458.25
Miscellaneous	8,587	KWH Used =	\$ 1,074.98
<b>Total Electric Usage</b>	<b>14,919,103</b>	<b>Electric Cost</b>	<b>\$ 830,457.97</b>

(All Totals Expressed In Million Gallons)

Water Totals	High Service Discharge				
Raw Water	11,693.07	Average HSD	27.95	Monroe Street	4,664
Filtered water	10,815.11	Max. Day HSD	38.49	Superior Street	1,040
Filter Wash Water	460.025	Min. Day HSD	23.21	St. Mary's Main	2,505
Plant Service Water	187.97	Max. Hour HSD	56.55	St. Joseph main	1,995
		Min. Hour HSD	8.10	<b>Total HSD</b>	<b>10,203.68</b>

Total Operational Cost                   \$ 3,681,227.91

Cost per Million Gallons of Water Filtered                   \$340.38

-----  
Chemical Cost. MG Filtered                   \$231.64

**Three Rivers Filtration Plant  
Fort Wayne, IN**

**Chemical Cost Summary**

2009

Year	Chemical Cost	Water Filtered	Cost per Million Gallons
		MGD	
1934	\$35,381.81	3,154.55	\$11.22
1935	\$48,895.19	3,119.92	\$15.67
1936	\$57,585.15	3,984.47	\$14.45
1937	\$47,758.65	3,724.68	\$12.82
1938	\$47,809.07	3,619.82	\$13.21
1939	\$45,152.49	3,849.42	\$11.73
1940	\$57,569.98	4,059.02	\$14.18
1941	\$68,771.06	4,590.91	\$14.98
1942	\$106,715.84	4,679.19	\$22.81
1943	\$110,314.17	5,577.50	\$19.78
1944	\$126,496.16	6,457.60	\$19.59
1945	\$134,580.84	6,238.63	\$21.57
1946	\$126,966.58	6,082.70	\$20.87
1947	\$154,064.30	6,590.82	\$23.38
1948	\$180,123.24	6,746.65	\$26.70
1949	\$174,751.21	6,420.99	\$27.22
1950	\$158,011.01	6,398.35	\$24.70
1951	\$172,914.84	6,689.94	\$25.85
1952	\$184,820.20	6,981.70	\$26.47
1953	\$212,013.20	7,306.36	\$29.02
1954	\$237,588.42	7,249.82	\$32.77
1955	\$226,050.52	7,546.06	\$29.96
1956	\$235,953.22	7,570.78	\$31.17
1957	\$265,174.39	7,579.69	\$34.98
1958	\$251,313.38	7,321.75	\$34.32
1959	\$259,409.91	7,756.36	\$33.44
1960	\$230,564.26	7,519.68	\$30.66
1961	\$251,616.87	7,540.33	\$33.37
1962	\$275,123.25	8,210.13	\$33.51
1963	\$301,030.38	8,742.56	\$34.43
1964	\$200,003.41	9,001.75	\$22.22
1965	\$346,148.03	9,254.28	\$37.40
1966	\$344,808.34	9,892.96	\$34.85
1967	\$370,878.28	10,108.39	\$36.69
1968	\$339,457.32	10,035.63	\$33.83
1969	\$355,628.89	10,635.23	\$33.44
1970	\$402,529.59	10,885.04	\$36.98
1971	\$397,163.97	10,726.17	\$37.03
1972	\$453,786.88	11,046.13	\$41.08
1973	\$398,938.48	11,318.51	\$35.25
1974	\$464,426.09	11,344.83	\$40.94
1975	\$644,033.93	11,179.75	\$57.61
1976	\$679,380.47	11,437.47	\$59.40
1977	\$858,842.50	12,145.15	\$70.71
1978	\$863,162.38	11,788.24	\$73.22
1979	\$1,048,484.60	11,468.97	\$91.42
1980	\$1,131,610.15	11,407.74	\$99.20
1981	\$1,064,717.44	11,935.65	\$89.20
1982	\$1,119,039.76	11,567.06	\$96.74

**Three Rivers Filtration Plant  
Fort Wayne, IN**

<b>Year</b>	<b>Chemical Cost</b>	<b>Water Filtered MGD</b>	<b>Cost per Million Gallons</b>
1983	\$1,074,667.63	11,861.72	\$90.60
1984	\$1,051,105.78	11,181.24	\$94.01
1985	\$1,065,180.54	11,943.77	\$89.18
1986	\$1,039,292.63	11,479.10	\$90.54
1987	\$1,037,592.72	11,878.01	\$87.35
1988	\$1,152,506.09	12,351.24	\$93.31
1989	\$1,035,326.47	11,802.45	\$87.72
1990	\$1,019,260.62	11,330.28	\$89.96
1991	\$1,068,617.31	11,973.09	\$89.25
1992	\$1,330,435.40	11,283.26	\$117.91
1993	\$1,452,473.40	11,749.16	\$123.62
1994	\$1,408,240.15	12,254.47	\$114.92
1995	\$1,535,596.59	12,396.14	\$123.88
1996	\$1,886,445.94	12,236.84	\$154.16
1997	\$1,721,512.61	11,766.61	\$148.74
1998	\$1,638,423.17	12,359.77	\$132.56
1999	\$1,431,155.89	12,844.67	\$111.42
2000	\$1,306,744.47	12,138.85	\$107.65
2001	\$1,360,731.16	11,903.66	\$114.31
2002	\$1,324,804.59	12,090.42	\$109.57
2003	\$1,289,380.67	11,267.43	\$114.43
2004	\$1,389,033.95	11,030.51	\$125.93
2005	\$1,501,237.01	10,750.89	\$139.64
2006	\$1,746,343.12	10,162.64	\$171.84
2007	\$1,920,070.03	10,982.46	\$174.83
2008	\$2,211,876.91	10,954.22	\$201.92
2009	\$2,505,253.61	10,815.11	\$231.64

# Three Rivers Filtration Plant Fort Wayne, IN

## Worksheet for Theoretical Lime, Soda Ash, and Sludge 2009

### 1. Raw Water Data

Free CO <sub>2</sub> =	4.02 mg/L (Calculated, Std. Methods, 21ST Ed.)	
Temperature	54.40 ° F=	12.4 ° C
Total Solids=	293.88 mg/L	
pH =	7.99 SU	
Alkalinity=	197.07 mg/L as CaCO <sub>3</sub>	
Raw Bicarb=	195.23 mg/L as CaCO <sub>3</sub>	

### 2. Conversion of mg/L TO me/L

	Raw Water	67.65 mg/L Ca=	3.3826 me/L Ca
		21.15 mg/L Mg=	1.7624 me/L Mg
		118.24 mg/L CO <sub>3</sub> =	3.9409 me/L CO <sub>3</sub>
	HSD(Finished Water)	31.80 mg/L Ca=	1.5900 me/L Ca
		8.26 mg/L Mg=	0.6887 me/L Mg
		0.00 mg/L CO <sub>3</sub> =	0.0000 me/L CO <sub>3</sub>

### 3. Hypothetical Combinations

	Raw Water	3.3826 me/L Ca=	169.30 mg/L CO <sub>3</sub>
		3.9409 me/L CO <sub>3</sub>	
		(3.3826) me/L Ca	
		0.5584 me/L Mg=	23.54 mg/L MgCO <sub>3</sub>
		1.7624 me/L Mg	
		0.5584 me/L Mg	
		1.2041 me/L Mg=	72.47 mg/L MgSO <sub>4</sub>
	HSD(Finished Water)	1.5900 me/L Ca=	79.58 mg/L MgCO <sub>3</sub>
		0.0000 me/L CO <sub>3</sub>	
		(1.5900) me/L Ca	
		0.0000 me/L Mg=	0.00 mg/L MgCO <sub>3</sub>
		0.6887 me/L Mg	
		0.0000 me/L Mg	
		0.6887 me/L Mg=	41.45 mg/L MgSO <sub>4</sub>

### 4. Noncarbonate Mg Reduction

Raw Water MgSO <sub>4</sub> =	72.47 mg/L	
HSD MgSO <sub>4</sub> =	(41.45) mg/L	
Reduction=	31.02 mg/L	6.27 mg/L Mg

### 5. Excess Lime Reduction

	Primary Settled Hydroxide	Secondary Settled Bicarbonate
Plant #1	40.32	28.40
Plant #2	39.96	29.52
Plant #3	22.60	19.57
Average	34.3	25.8
Total Excess Lime Reduction=	8.5 mg/L CaCO <sub>3</sub>	

### 6. Noncarbonate Hardness Reduction

Raw Water Noncarbonate Hardness=	60.18 mg/L CaCO <sub>3</sub>	
HSD Noncarbonate Hardness=	74.09 mg/L CaCO <sub>3</sub>	
Total Noncarb Hardness Reduction=	(13.9) mg/L CaCO <sub>3</sub>	

### 7. Suspended Matter

Raw Water Turbidity	47.98 NTU=	2.80 gpg
Carbon Application	4.31 mg/L=	0.25 gpg
Total Suspended Matter=	52.29 mg/L=	3.05 gpg

# Three Rivers Filtration Plant Fort Wayne, IN

## Theoretical Lime, Soda Ash, and Sludge Annual- 2009

### I. Theoretical Lime

For Raw Water Free CO <sub>2</sub> =	4.02 mg/L	0.30 gpg CaO
For Raw Water Hypothetical CaCO <sub>3</sub>	169.30 mg/L	5.54 gpg CaO
For Raw Water Hypothetical MgCO <sub>3</sub>	23.54 mg/L	1.83 gpg CaO
For Noncarb Mg Reduction=	6.27 mg/L	0.84 gpg CaO
For Ferric Sulfate Application=	1.87 gpg	0.56 gpg CaO
For Primary Settled Hydroxide (OH-)	34.30 mg/L as CaCO <sub>3</sub>	1.12 gpg CaO
	Total=	10.19 gpg CaO

Total Theoretical Lime(95.55% Purity)= **11.02 gpg versus 10.08 gpg CaO Applied**

### II. Theoretical Soda Ash

For Noncarb Hardness Reduction	(13.90) mg/L=	(0.86) gpg
For Ferric Sulfate Application	1.87 gpg=	1.05 gpg
	Total=	0.00 gpg
Total Soda Ash=	<b>0.00 gpg versus</b>	<b>0.00 gpg Soda Ash Applied</b>

### III. Theoretical Sludge

#### A. From Precipitated Products of Chemical Reactions

1. Raw Water Free CO <sub>2</sub>	0.30 gpg=	0.53 gpg CaCO <sub>3</sub>	
2. Raw Water Hypothetical CaCO <sub>3</sub>	5.54 gpg=	19.76 gpg CaCO <sub>3</sub>	
3. Raw Water Hypothetical MgCO <sub>3</sub>	1.83 gpg=	3.26 gpg CaCO <sub>3</sub>	
4. Ferric Sulfate Application	0.56 gpg=	0.99 gpg CaCO <sub>3</sub>	
5. Soda Ash for Noncarbonate Reduction	(0.86) gpg=	0.00 gpg CaCO <sub>3</sub>	
6. Excess Lime Recarbonation	9.1 mg/L=	0.53 gpg CaCO <sub>3</sub>	84.06% CaCO <sub>3</sub>
7. Raw Water Hypothetical MgCO <sub>3</sub>	1.83 gpg=	0.66 gpg MgO	
8. Noncarb Mg Reduction	0.84 gpg=	0.61 gpg MgO	4.24% MgO
9. Ferric Sulfate Application	1.87 gpg=	0.53 gpg Fe <sub>2</sub> O <sub>3</sub>	1.78% Fe <sub>2</sub> O <sub>3</sub>
Total Precipitated Products=	26.88 gpg		

#### B. From Suspended Matter

1. Raw Water Turbidity	47.98	NTU =	2.80 gpg	9.39% Turbidity
2. Added Carbon Application	4.31	mg/L=	0.16 gpg	0.54% Carbon
Total Suspended Matter=			2.96 gpg	

### IV. Summary

<b>Total Precipitated Products, gpg =</b>	<b>26.88</b>
<b>Total Suspended Matter, gpg=</b>	<b>2.96</b>
<b>Total Theoretical Sludge, gpg=</b>	<b>29.84</b>
<b>Pounds of Sludge per MG of Raw Water</b>	<b>4,260.3</b>
<b>Tons of Sludge per MG of Raw Water</b>	<b>2.13</b>
<b>Raw Water Treated in MG</b>	<b>11,693.07</b>
<b>Tons of Sludge per Day</b>	<b>68.24</b>
<b>Total Tons of Sludge Generated in 2009</b>	<b>24,908</b>

**Three Rivers Filtration Plant  
Fort Wayne, IN**

**Sludge Data**

Year of Record	Raw Water Pumpage MG	Tons per MG	Total Sludge Tons	Sludge Composition				
				CaCO(3) %	MgO %	Fe(2)O(3) %	Turbidity %	Carbon %
1953	7,431.55	2.65	19,694	85.39	4.48	0.35	9.02	0.76
1954	7,344.32	2.63	19,316	81.36	3.51	0.46	13.72	0.95
1955	7,594.29	2.51	19,062	85.33	3.57	0.34	9.73	1.03
1956	7,660.74	2.54	19,458	80.01	3.67	0.39	14.72	1.21
1957	7,728.25	2.53	19,552	82.14	3.75	0.42	12.81	0.88
1958	7,499.12	2.61	19,573	82.57	3.65	0.52	12.14	1.12
1959	7,982.38	2.36	18,838	81.31	3.69	0.55	12.66	1.79
1960	7,757.98	2.52	19,550	82.20	3.88	0.40	12.39	1.13
1961	7,763.23	2.49	19,330	84.01	4.07	0.37	10.29	1.26
1962	8,543.64	2.39	20,419	85.96	4.55	0.45	7.12	1.92
1963	8,911.06	2.62	23,347	86.37	5.08	0.30	6.50	1.75
1964	9,167.09	2.78	25,485	84.69	4.74	0.23	9.28	1.06
1965	9,419.50	2.82	26,563	79.20	3.93	0.33	15.22	1.32
1966	10,052.50	2.72	27,343	76.65	4.20	0.16	17.23	1.76
1967	10,259.84	2.51	25,752	83.49	4.24	0.28	10.85	1.14
1968	10,205.78	2.57	26,229	80.52	3.72	0.31	14.12	1.33
1969	10,898.68	2.44	26,592	82.23	1.14	2.25	13.15	1.23
1970	11,329.55	2.46	27,870	82.04	4.37	0.23	12.05	1.31
1971	11,249.67	2.32	26,099	82.24	4.22	0.25	11.87	1.42
1972	11,332.68	2.73	30,938	76.73	3.10	0.26	18.57	1.34
1973	11,732.16	2.54	29,800	76.46	3.69	0.25	18.50	1.10
1974	11,833.83	2.43	28,756	75.87	3.88	0.21	19.13	0.91
1975	11,548.48	2.62	30,257	70.30	3.89	0.23	24.73	0.85
1976	11,872.06	2.24	26,593	82.60	5.34	0.14	11.12	0.80
1977	12,574.05	2.61	32,818	80.16	5.00	0.22	13.83	0.79
1978	12,097.31	2.57	31,090	85.57	4.70	0.31	8.67	0.75
1979	11,422.65	2.63	30,022	82.51	4.71	0.49	11.26	1.03
1980	10,845.22	2.75	29,824	75.10	3.82	0.42	19.49	1.17
1981	11,550.48	2.82	32,572	77.11	4.23	0.48	17.42	0.76
1982	11,748.08	2.63	30,897	73.20	3.77	0.52	21.50	1.01
1983	12,004.75	2.50	30,012	80.22	4.52	0.32	14.14	0.80
1984	11,526.26	2.43	28,009	80.33	4.54	0.41	13.75	0.97
1985	12,073.02	2.48	29,941	78.17	4.04	0.49	16.41	0.89
1986	11,432.38	2.60	29,724	76.58	3.44	0.50	18.52	0.96
1987	11,763.80	2.64	31,056	84.07	4.47	0.22	10.40	0.84
1988	12,657.76	2.76	34,952	81.95	3.65	0.39	12.84	1.17
1989	11,802.45	2.62	30,922	77.13	4.99	0.35	16.88	0.65
1990	11,281.23	2.37	26,681	83.17	3.64	0.33	11.74	1.12
1991	11,883.10	2.40	28,462	86.89	4.21	0.39	7.70	0.81
1992	11,218.54	1.92	21,520	83.49	3.35	1.10	10.91	1.14
1993	11,666.67	2.16	25,206	87.62	2.64	1.23	7.22	1.29
1994	12,244.40	2.49	30,478	89.19	4.72	1.05	3.69	1.34
1995	12,300.68	2.36	28,995	88.28	4.42	1.18	4.89	1.23
1996	12,744.18	2.35	29,866	83.05	4.75	2.12	8.03	2.04
1997	12,349.40	2.34	28,931	81.48	3.37	2.67	10.73	1.75
1998	13,078.29	3.49	45,605	80.90	5.18	2.68	10.47	0.77
1999	13,684.57	2.26	30,902	84.87	5.54	1.98	7.12	0.50
2000	13,377.92	2.37	31,687	87.49	4.67	1.65	5.71	0.48
2001	12,725.04	2.24	28,534	85.07	4.11	2.21	8.12	0.49
2002	12,909.75	2.41	28,647	86.51	4.46	1.49	7.07	0.47
2003	12,040.46	2.27	27,355	85.21	3.87	2.61	7.81	0.50
2004	11,898.44	2.19	26,001	84.49	5.15	2.31	7.53	0.52
2005	12,142.29	2.16	26,215	87.29	5.13	2.17	4.89	0.53
2006	11,429.44	2.05	23,473	84.47	4.32	2.11	8.54	0.56
2007	12,254.23	2.22	27,217	85.42	4.49	1.66	7.90	0.51
2008	11,841.94	2.12	25,132	84.07	4.69	1.91	8.80	0.54
2009	11693.07	2.13	24,908	84.06	4.24	1.78	9.39	0.54

Three Rivers Filtration Plant  
Fort Wayne, IN  
Rain Fall Data  
2009

	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	Average
<b>January</b>	2.78	1.25	0.74	2.46	1.30	2.43	4.96	3.01	3.74	2.23	1.07	2.36
<b>February</b>	2.51	1.57	2.73	1.8	1.39	0.54	2.47	1.64	0.96	4.73	3.70	2.19
<b>March</b>	1.14	2.01	0.48	2.56	2.43	2.79	1.46	1.98	3.39	3.82	5.70	2.52
<b>April</b>	6.37	2.09	3.59	3.70	2.35	1.15	2.15	4.26	3.47	1.98	5.94	3.37
<b>May</b>	3.94	4.63	2.56	6.29	6.94	6.71	1.70	5.04	1.10	4.95	2.01	4.17
<b>June</b>	1.07	8.55	4.26	3.13	3.66	5.30	2.13	3.36	3.04	5.55	3.75	3.98
<b>July</b>	1.07	2.18	6.70	2.40	9.80	5.51	5.19	5.41	1.82	3.15	4.22	4.31
<b>August</b>	3.1	3.68	4.56	2.79	4.08	5.19	1.95	3.11	9.69	2.06	4.24	4.04
<b>September</b>	1.03	4.61	4.04	2.54	5.44	1.75	3.97	2.03	2.47	1.83	1.41	2.83
<b>October</b>	2.32	1.78	7.40	1.58	2.01	1.73	0.51	4.35	1.91	2.32	5.17	2.83
<b>November</b>	1	2.12	2.30	2.27	2.42	3.39	3.29	2.39	4.21	2.03	1.14	2.41
<b>December</b>	1.95	2.54	2.40	1.61	2.62	2.67	2.16	4.73	4.45	4.34	2.77	2.93
<b>total</b>	28.28	37.01	41.76	33.13	44.44	39.16	31.94	41.31	40.25	38.99	41.12	37.94

Analysis for Year 2009

Physical and Chemical Characteristics	Raw Water Maximum	Raw Water Minimum	Raw Water Average	Finished Water Maximum	Finished Water Minimum	Finished Water Average	EPA Limit	Standard Type
Temperature, F	77.0	34.0	54.4				—	—
Turbidity, NTU	319.00	5.00	47.98	0.45	0.03	0.05	0.30	Primary
Color, Cobalt Scale Unit	800.00	20.00	120.28	10.00	0.00	0.55	15.0	Secondary
pH	8.30	7.60	7.99	9.60	8.20	8.77	6.5-8.5	Secondary
Specific Conductance, Micromhos	565.60	252.00	414.40	292.60	188.00	237.81	—	—
Total Dissolved Solids, mg/L	353.60	241.20	293.88	239.60	169.00	202.57	500.0	Secondary
Total Alkalinity, mg/L as CaCO3	262.00	80.00	197.07	80.00	24.00	35.78	—	—
Noncarbonate Hardness,	129.00	26.00	60.18	132.00	45.00	74.09	—	—
Total Hardness,	384.00	123.00	257.25	177.00	75.00	109.87	—	—
Langlier's Index				0.36	-0.11	0.11	Non-Corrosive	Secondary
Chloride, (Cl)	38.96	15.43	28.11	41.19	18.80	30.56	250.0	Secondary
Cyanide, (CN)	0.00	0.00	0.00	0.00	0.00	0.00	0.2	Primary
Fluoride, FI	0.46	0.07	0.30	1.08	0.91	0.98	4.00	Primary
Nitrate, NO3	4.13	0.37	1.55	5.99	0.40	1.76	10.00	Primary
Nitrite, NO2	2.96	0.00	0.61	0.09	0.02	0.04	1.00	Primary
Phosphate, PO4							—	—
Sulfate, SO4	68.48	25.33	47.06	76.49	38.59	56.67	250.0	Secondary
Surfactants, MBAS	0.07	0.02	0.04	0.06	0.01	0.04	0.5	Secondary
Asbestos						Not Detected	7 MFL	Primary
<b>Metals</b>								
Aluminum	6.860	0.245	1.437	0.069	0.000	0.015	0.05-0.2	Secondary
Antimony	0.000	0.000	0.000	0.000	0.000	0.000	0.006	Primary
Arsenic	0.003	0.001	0.002	0.000	0.000	0.000	0.010	Primary
Barium	0.077	0.029	0.061	0.012	0.000	0.007	2.00	Primary
Beryllium	0.003	0.000	0.001	0.0000	0.0000	0.0000	0.004	Primary
Cadmium	0.002	0.000	0.001	0.0002	0.0000	0.0002	0.005	Primary
Calcium	78.000	37.700	65.042	37.900	23.800	28.175	—	—
Chromium	0.012	0.012	0.012	0.000	0.000	0.000	0.10	Primary
Copper	0.000	0.000	0.000	0.000	0.000	0.000	Action Level 1.3*	Primary
Iron	5.060	0.467	1.553	0.040	0.000	0.003	0.3	Secondary
Lead	0.003	0.000	0.002	0.000	0.000	0.000	Action Level 0.015*	Primary
Magnesium	22.000	9.570	16.814	11.900	4.540	6.867	—	—
Manganese	0.100	0.012	0.056	0.000	0.000	0.000	0.050	Secondary
Mercury	0.000	0.000	0.000	0.000	0.000	0.000	0.002	Primary
Molybdenum	0.013	0.004	0.008	0.010	0.003	0.007	—	—
Nickel	0.017	0.011	0.015	0.000	0.000	0.000	—	—
Potassium	6.700	2.910	4.823	6.400	2.750	4.417	—	—
Selenium	0.000	0.000	0.000	0.000	0.000	0.000	0.05	Primary
Silicon	10.200	1.300	4.029	2.640	1.250	2.058	—	—
Silver	0.000	0.000	0.000	0.000	0.000	0.000	0.100	Secondary
Sodium	37.600	5.570	17.514	22.700	5.850	15.846	—	—
Thallium	0.000	0.000	0.000	0.000	0.000	0.000	0.002	Primary
Tin	0.013	0.000	0.003	0.006	0.000	0.001	—	—
Zinc	0.027	0.000	0.005	0.000	0.000	0.000	5	Secondary
Radioactivity (Radium 228) pCi/L	LAST TESTING PERIOD 2008			NA	NA	1.7	5	Primary

All Constituents Expressed As mg/L (ppm) Unless Otherwise Noted

Lead-Copper In Distribution Samples	90 % Level	EPA Limit	Standard Type
Lead	0.015 mg/L	Action Level 0.015 mg/L*	Primary
Copper	0.13 mg/L	Action Level 1.3 mg/L*	Primary

\* = Treatment Technology Action Level. 90% of the distribution system samples must have Lead and Copper Concentration at or below the action level.

# Three Rivers Filtration Plant Fort Wayne, IN

## Microbiological Summary 2009

### Heterotrophic Plate Count, CFU/mL

	<u>Raw</u>	<u>Plant 1</u>	<u>Plant 2</u>	<u>Plant 3</u>	<u>Finished Water</u>
Primary Settled	-----	97	133	23	
Secondary Settled	-----	7	13	6	
Filtered	-----	2	1	1	
Avg	7787	-----	-----	-----	13
Max	23688	-----	-----	-----	128
Min	1950	-----	-----	-----	0

### Coliform and Fecal Coliform, Most Probable Number Indices

	<u>Raw</u>	<u>Plant 1 Primary</u>	<u>Plant 1 Secondary</u>	<u>Plant 2 Primary</u>	<u>Plant 2 Secondary</u>	<u>Plant 3 Primary</u>	<u>Plant 3 Secondary</u>
Coliform Index	6,804.5	25.1	2.7	19.7	0.9	21.6	1.6
Fecal Coliform Index	252.9	2.7	0.0	4.2	0.0	0.5	0.0
<b>Raw Coli</b>		<b>Fecal</b>					
Max	17,540.0	542.9					
Min	1,665.0	37.5					

### Post Coliaerogenes

	<u>#1 Filter</u>	<u>#2 Filter</u>	<u>#3 Filter</u>	<u>Finished Water</u>	<u>City Tap</u>
Number of test Days	99	99	100	365	248
Number of Samples	99	99	100	1,460	2,002
Confirmed Coliform Samples	0	0	0	1	1
Coliform, % Positive	0.00	0.00	0.00	0.07	0.05

### Main and Service Samples

65

### Other Microbial Contaminants

	<u>Raw Water</u>	<u>No. of tests</u>	<u>Finished Water</u>	<u>No. of tests</u>
	<u>AVE.</u>		<u>AVE.</u>	
Cryptosporidium, oocyst/100 L	0.193	12	0.000	12
Giardia, cyst/ 100L	0.133	12	0.000	12

## Three Rivers Filtration Plant Fort Wayne, IN

Annual 2009

### SPECIAL SUMMARY

LIME SOFTENING SUMMARY

T. ALK

HYDROXIDE

BICARBONATE  
(as CaCO<sub>3</sub>)

-----  
RAW 197.1 - 197.1  
-----

PLANT #1  
-----

PRIMARY SETTLED 40.0 0.0  
CARBONATED 0.0 32.0  
SECONDARY SETTLED 0.0 28.0

PLANT #2  
-----

PRIMARY SETTLED 39.5 0.0  
CARBONATED 0.0 32.2  
SECONDARY SETTLED 0.0 29.7

PLANT #3  
-----

PRIMARY SETTLED 33.9 0.0  
CARBONATED 0.0 26.6  
SECONDARY SETTLED 0.0 26.9

H.S.D. 35.8

#### NON-CARBONATE SUMMARY

#### COLOR SUMMARY

-----  
RAW 60.2 120.3  
-----

H.S.D. 74.1 0.5

	RAW	FILTER #1	FILTER #2	FILTER #3	H.S.D.	CITY TAP
# OF TEST DAYS	365	365	365	365	365	248
TURBIDITY	48.0	0.06	0.04	0.07	0.05	-
pH	8.0	-	-	-	8.8	-
T. HARD. mg/L	257.3	-	-	-	109.9	-
T. HARD. gpg	15.0	-	-	-	6.4	-
FLUORIDE	0.3				1.0	1.0

DISSOLVED SOLIDS (IN mg/L)

RAW

H.S.D.

	Maximum	Minimum	Average	Maximum	Minimum	Average
TOTAL SOLIDS	353.6	241.2	293.9	239.6	169.0	202.6
FIXED SOLIDS	270.4	172.2	215.7	187.8	124.6	151.1
VOLATILE SOLIDS	109.2	58.6	78.2	62.4	42.0	51.5
SPECIFIC CONDUCTANCE	565.6	252.0	414.4	292.6	188.0	237.8

**Three Rivers Filtration Plant  
Fort Wayne, IN**

**2009 Purification Chemicals Summary**

Lime Suppliers: Huron Lime

**Slaking Analysis**

	%CaO	Rise In 3 Minutes °C	Maximum Temperature °C	Minimum Temperature °C	Minutes to Max. Temp.
Maximum	99.9%	97.00	97.00	27.00	7.00
Minimum	90.0%	40.00	59.00	10.00	3.00
Average	96.0%	67.56	81.94	20.46	3.87

**Principal Constituents, In mg/L**

	Maximum	Raw Minimum	Average	Maximum	H.S.D. Minimum	Average
Sulfate, SO <sub>4</sub>	68.48	25.33	47.06	76.49	38.59	56.67
Chloride, Cl	38.96	15.43	28.11	41.19	18.80	30.56
Fluoride, F	0.46	0.07	0.30	1.08	0.91	0.98
Nitrate, NO <sub>2</sub> as N	4.13	0.37	1.55	5.99	0.40	1.76
Nitrite, NO <sub>3</sub> as N	2.96	0.00	0.61	0.09	0.02	0.04

**Special Analysis**

	Maximum	Raw Minimum	Average	Maximum	H.S.D. Minimum	Average
Langlier's Index	N/A	N/A	N/A	0.36	(0.11)	0.11
MBAS, mg/L	0.07	0.02	0.04	0.06	0.01	0.04

**Chlorine Residual**

	<u>Filter # 1</u>	<u>Filter # 2</u>	<u>Filter # 3</u>	<u>H.S.D</u>	<u>City Tap</u>
Number of Test days	365	365	365	365	365
Number of Tests	365	365	365	365	2,101
Average Residual, mg/L	1.62	1.75	1.85	1.43	0.98

**Temperature**

	Maximum	Minimum	Average	Total
Water Temperature, °F	72.71	36.13	54.40	
Weather Bureau Mean, °F	70.50	16.60	49.78	
Degree Days	1,494.00	0.00	504.83	
Rain Fall	5.94	1.07	3.43	41.12

**Three Rivers Filtration Plant  
Fort Wayne, IN**

**Disinfection Byproducts and Precursors**

sampling pt: 7916 W Jefferson Sample Date Chemical	Method	MCL ug/L	2009				Average ug/L
			01/07/09 ug/L	04/16/09 ug/L	08/12/09 ug/L	11/05/09 ug/L	
<b><u>Trihalomethanes (THM)</u></b>							
Chloroform	524.2		29.0	18	10.0	43	25.0
Bromoform	524.2		<0.5	<0.5	<0.5	< 0.5	< 0.5
Bromodichloromethane	524.2		2.4	0.8	1.9	2.7	2.0
Dibromochloromethane	524.2		<0.5	<0.5	<0.5	< 0.5	< 0.5
<b>Total Trihalomethanes</b>		<b>80</b>	<b>31.4</b>	<b>18.8</b>	<b>11.9</b>	<b>45.7</b>	<b>27.0</b>
<b><u>HAA</u></b>							
Monochloroacetic Acid	552.2		4.0	3.5	< 2.0	2.1	2.4
Dichloroacetic Acid	552.2		27.0	14	8.7	19	17.2
Trichloroacetic Acid	552.2		3.4	1.7	< 1.0	4.5	2.4
Monobromoacetic Acid	552.2		<1.0	<1.0	<1.0	< 1.0	< 1.0
Dibromoacetic Acid	552.2		<1.0	<1.0	<1.0	< 1.0	< 1.0
<b>Total HAA=</b>		<b>60</b>	<b>34.4</b>	<b>19.2</b>	<b>8.7</b>	<b>25.6</b>	<b>22.0</b>
<b><u>Inorganic Disinfection Byproducts</u></b>							
Chlorite	300	1000	950.0	770	480	840	760.0

## Three Rivers Filtration Plant Fort Wayne, IN

### Samples Analyzed By

Laboratory: Underwriters Laboratories

Lab Cert #: C-71-01

### Insecticides and Pesticides

Compound ID#	Sample Date Chemical	Method	MCL ug/L	First Quarter 10-Feb-09 ug/L	Second Quarter 12-May-09 ug/L	Third Quarter 11-Aug-09 ug/L	Fourth Quarter 10-Nov-09 ug/L	2009 Average ug/L
<b>Regulated Contaminants</b>								
2051	Alachlor	525.2	2	<0.1	<0.1	< 0.1	< 0.1	< 0.1
2050	Atrazine	525.2	3	<0.1	<0.1	<b>0.3</b>	0.10	<b>0.08</b>
2306	Benzo(A)pyrene	525.2	<b>0.2</b>	<0.02	<0.02	< 0.02	< 0.02	< 0.02
2046	Carbofuran	531.1	<b>40</b>	<0.9	<0.9	< 0.9	< 0.9	< 0.9
2069	Chlordane, (alpha+gamma)	505	2	<0.1	<0.1	< 0.1	< 0.1	< 0.1
2105	2,4-D	515.3	<b>70</b>	<0.1	<0.1	< 0.1	< 0.1	< 0.1
2031	Dalapon	515.3	<b>200</b>	<1.0	<1.0	< 1.0	< 1.0	< 1.0
2931	1,2-Dibromo-3-chloropropane-DBCP	504	<b>0.2</b>	<0.01	<0.01	< 0.01	< 0.01	< 0.01
2041	Dinoseb	515.3	7	<0.1	<0.1	< 0.1	< 0.1	< 0.1
2063	2,3,7,8-TCDD(Dioxine)	1613b	<b>3e=05</b>	<5.0e-06	<5.0e-06	<5.0e-06	<5.0e-06	<5.0e-06
2032	Diquat	549.2	<b>20</b>	<0.4	<0.4	< 0.4	< 0.4	< 0.4
2035	Dil(2-ethylhexyl)adipate	525.2	<b>400</b>	<0.6	<0.6	< 0.6	< 0.6	< 0.6
2039	Dil(2-ethylhexyl)phthalate	525.2	<b>6</b>	<0.6	<0.6	< 0.6	< 0.6	< 0.6
2033	Endothall	548	<b>100</b>	<9.0	<9.0	< 9.0	< 9.0	< 9.0
2005	Endrin	525.2	2	<0.01	<0.01	< 0.01	< 0.01	< 0.01
2946	Ethylene Dibromide (EDB)	504	<b>0.05</b>	<0.01	<0.01	< 0.01	< 0.01	< 0.01
2034	Glyphosate	547	<b>700</b>	<6.0	<6.0	< 6.0	< 6.0	< 6.0
2065	Heptachlor	525.2	<b>0.4</b>	<0.04	<0.04	< 0.04	< 0.04	< 0.04
2067	Heptachlorepoide	525.2	<b>0.2</b>	<0.02	<0.02	< 0.02	< 0.02	< 0.02
2274	Hexachlorobenzene	525.2	1	<0.1	<0.1	< 0.1	< 0.1	< 0.1
2042	Hexachlorocyclopentadiene	525.2	<b>50</b>	<0.1	<0.1	< 0.1	< 0.1	< 0.1
2010	Lindane	525.2	<b>0.2</b>	<0.02	<0.02	< 0.02	< 0.02	< 0.02
2015	Methoxychlor	525.2	<b>40</b>	<0.1	<0.1	< 0.1	< 0.1	< 0.1
2036	Oxamyl (Vydate)	531.1	<b>200</b>	<1.0	<1.0	< 1.0	< 1.0	< 1.0
2326	Pentachlorophenol	515.3	<b>1</b>	<0.04	<0.04	< 0.04	< 0.04	< 0.04
2040	Picloram(Tordon)	515.3	<b>500</b>	<0.1	<0.1	< 0.1	< 0.1	< 0.1
2383	Polychlorinated Biphenyls-PCB	505.0	<b>0.5</b>	<0.5	<0.5	< 0.5	< 0.5	0.00
2037	Simazine	525.2	<b>4</b>	<0.07	<0.07	< 0.07	< 0.07	< 0.07
2110	2,4,5-TP (Silvex)	515.3	<b>50</b>	<0.1	<0.1	< 0.1	< 0.1	< 0.1
2020	Toxaphene	505	<b>3</b>	<1.0	<1.0	< 1.0	< 1.0	< 1.0
<b>Unregulated Contaminants</b>								
2047	Aldicarb	531.1	N/A	<0.5	<0.5	<0.5	<0.5	<0.5
2044	Aldicarb Sulfone	531.1	N/A	<0.7	<0.7	<0.7	<0.7	<0.7
2043	Aldicarb Sulfoxide	531.1	N/A	<0.5	<0.5	<0.5	<0.5	<0.5
2356	Aldrin	525.2	N/A	<0.1	<0.1	<0.1	<0.1	<0.1
2076	Butachlor	525.2	N/A	<0.1	<0.1	<0.1	<0.1	<0.1
2021	Carbaryl	531.1	N/A	<0.5	<0.5	<0.5	<0.5	<0.5
2440	Dicamba	515.3	N/A	<0.1	<0.1	<0.1	<0.1	<0.1
2070	Dieldrin	525.2	N/A	<0.1	<0.1	<0.1	<0.1	<0.1
2066	3-Hydroxycarbofuran	531.1	N/A	<0.5	<0.5	<0.5	<0.5	<0.5
2022	Methomyl	531.1	N/A	<0.5	<0.5	<0.5	<0.5	<0.5
2045	Metolachlor(Dual)	525.2	N/A	<b>&lt;0.1</b>	<b>&lt;0.1</b>	<b>0.10</b>	< 0.1	0.03
2595	Metribuzin (Sencor)	525.2	N/A	<0.1	<0.1	<0.1	<0.1	<0.1
2077	Propachlor	525.2	N/A	<0.1	<0.1	<0.1	<0.1	<0.1

## Three Rivers Filtration Plant Fort Wayne, IN

Samples Analyzed By

Laboratory: Underwriters Laboratories

Lab Cert #: C-71-01

### Volatile Organic Compounds (VOC)

Compound ID#	Sample Date Chemical Sample location: 1100 Griswold	Method	MCL ug/L	First Quarter 07-Jan-09 ug/L	Second Quarter 16-Apr-09 ug/L	Third Quarter 19-Aug-09 ug/L	Fourth Quarter 05-Nov-09 ug/L	2009 Average ug/L	
<b><u>Regulated Contaminants</u></b>									
2990	Benzene	524.2	5	<0.5	<0.5	<0.5	< 0.5	< 0.5	
2982	Carbon tetrachloride	524.2	5	<0.5	<0.5	<0.5	<0.5	<0.5	
2989	Chlorobenzene	524.2	100	<0.5	<0.5	<0.5	<0.5	<0.5	
2968	1,2-Dichlorobenzene	524.2	600	<0.5	<0.5	<0.5	<0.5	<0.5	
2969	1,4-Dichlorobenzene	524.2	75	<0.5	<0.5	<0.5	<0.5	<0.5	
2980	1,2-Dichloroethane	524.2	5	<0.5	<0.5	<0.5	<0.5	<0.5	
2977	1,1-Dichloroethylene	524.2	7	<0.5	<0.5	<0.5	<0.5	<0.5	
2380	1,2-Dichloroethylene,cis	524.2	70	<0.5	<0.5	<0.5	<0.5	<0.5	
2979	1,2-Dichloroethylene,trans	524.2	100	<0.5	<0.5	<0.5	<0.5	<0.5	
2964	Dichloromethane	524.2	5	<0.5	<0.5	<0.5	<0.5	<0.5	
2983	1,2-Dichloropropane	524.2	5	<0.5	<0.5	<0.5	<0.5	<0.5	
2992	Ethylbenzene	524.2	700	<0.5	<0.5	<0.5	<0.5	<0.5	
2996	Styrene	524.2	100	<0.5	<0.5	<0.5	<0.5	<0.5	
2987	Tetrachloroethylene	524.2	5	<0.5	<0.5	<0.5	<0.5	<0.5	
2991	Toluene	524.2	1000	<0.5	<0.5	<0.5	<0.5	<0.5	
2378	1,2,4-Trichlorobenzene	524.2	70	<0.5	<0.5	<0.5	<0.5	<0.5	
2981	1,1,1-Trichloroethane	524.2	200	<0.5	<0.5	<0.5	<0.5	<0.5	
2985	1,1,2-Trichloroethane	524.2	5	<0.5	<0.5	<0.5	<0.5	<0.5	
2984	Trichloroethylene	524.2	5	<0.5	<0.5	<0.5	<0.5	<0.5	
2976	Vinylchloride	524.2	2	<0.2	0.40	<0.2	<0.2	0.10	
2955	Total Xylenes	524.2	10,000	<0.5	<0.5	<0.5	ND	ND	
2995	1,3-Xylenes	524.2		<0.5	<0.5	<0.5	<0.5	<0.5	
2997	1,2-Xylenes	524.2		<0.5	<0.5	<0.5	<0.5	<0.5	
2962	1,4-Xylenes	524.2		<0.5	<0.5	<0.5	<0.5	<0.5	
<b>Total regulated Contaminants</b>				<b>&lt;0.5</b>	<b>0.40</b>	<b>&lt; 0.5</b>	<b>&lt; 0.5</b>	<b>0.10</b>	
<b><u>Unregulated Trihalomethanes</u></b>									
2408	Dibromomethane	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2943	Bromodichloromethane	524.2		1.20	0.70	3.40	3.00	2.08	
2942	Bromoform	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2944	Chlorodibromomethane	524.2		<0.5	<0.5	1.00	< 0.5	0.25	
2941	Chloroform	524.2		18.00	18.00	20.00	50.00	26.50	
<b>Total Trihalomethanes</b>				<b>80</b>	<b>19.20</b>	<b>18.70</b>	<b>24.40</b>	<b>53.00</b>	<b>28.83</b>
<b><u>Unregulated Contaminants</u></b>									
2993	Bromobenzene	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2214	Bromomethane	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2216	Chloroethane	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2210	Chloromethane	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2965	1,2-Chlorotoluene(o-)	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2966	1,4-Chlorotoluene(p-)	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2967	1,3-Dichlorobenzene	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2978	1,1-Dichloroethane	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2412	1,3-Dichloropropane	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2416	2,2-Dichloropropane	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2410	1,1-Dichloropropene	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2413	1,3-Dichloropropene (cis and trans)	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2986	1,1,1,2-Tetrachloroethane	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2988	1,1,2,2-Tetrachloroethane	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2414	1,2,3-Trichloropropane	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2408	Dibromomethane	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
2251	Methyl-t-butyl ether (MTBE)	524.2		<0.5	<0.5	< 0.5	< 0.5	< 0.5	
<b>Total Unregulated Contaminants</b>				<b>&lt;0.5</b>	<b>&lt;0.5</b>	<b>&lt; 0.5</b>	<b>&lt; 0.5</b>	<b>&lt; 0.5</b>	