

July 31, 2019

Dear Honeysuckle Water System Customer:

By now you should have received the Honeysuckle annual CCR. This letter serves as a reminder that you can contact Vicky Zehr at the Citizen Services Center by dialing 311 or (260) 427-8311 if you have any questions regarding the report. Additionally, we have enclosed some data that you may have seen in previous reports but did not see in this year's report. We were not required to test for these parameters in 2018, but thought you might still be interested in the results from previous years.

Fort Wayne City Utilities is committed to providing customers with the highest possible quality water at a reasonable price while protecting public health and the environment.

Sincerely,

Vicky Zehr Water Quality Supervisor Fort Wayne City Utilities Honeysuckle Site

Regulated Contaminants

Regulated Conta	mmants							
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	3/8/2017	0.19	0.19 - 0.19	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	3/8/2017	2	2-2	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	3/8/2017	0.7	0.7 - 0.7	4	4	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
			I D 0					
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Gross alpha excluding radon and	5/1/2017	1.09	1.09 - 1.09	0	15	pCi/L	N	Erosion of natural deposits.

ENGAGE • INNOVATE • PERFORM