



- "A" = SPACE REQUIRED FOR METER AND METER YOKE
 "B" = MINIMUM AND MAXIMUM DISTANCE FROM ϵ OF PIPING TO FLOOR OR OBSTRUCTION BELOW METER
 "C" = MINIMUM DISTANCE FROM ϵ OF PIPING TO WALL OR OBSTRUCTION BEHIND METER
 "D" = MINIMUM DISTANCE FROM ϵ OF PIPING TO CEILING OR PERMANENT OBSTRUCTION ABOVE METER

NORMAL PIPE SIZE	METER SIZE	"A"		"B"		"C"	"D"
3/4"	5/8" X 3/4"	11 3/4" MIN.	12" MAX.	6" MIN.	45" MAX.	6" MIN.	32" MIN.
3/4"	3/4"	13 1/4" MIN.	13 1/2" MAX.	6" MIN.	45" MAX.	7" MIN.	32" MIN.
1"	1"	15 1/4" MIN.	15 1/2" MAX.	6" MIN.	45" MAX.	7 1/2" MIN.	32" MIN.

NOTES:

- NO OBSTRUCTION SHALL BE PLACED IN FRONT OF METER WHICH CANNOT BE MOVED READILY FOR READING, REPAIR, OR REPLACEMENT OF METER.
- A COMPRESSION STOP AND WASTE VALVE OR BALL VALVE SHALL BE INSTALLED ON INLET SIDE OF METER WHERE SERVICE LINE IS UP TO 1".
- ALL METERS SHALL BE INSTALLED IN A HORIZONTAL POSITION WITH FACE OF READING DIAL ALSO HORIZONTAL. NO METER SHALL BE TILTED OR INSTALLED IN ANY OTHER POSITION WITHOUT WRITTEN CONSENT OF THE UTILITY.
- METER SHALL BE LOCATED SUCH THAT IT WILL NOT BE SUBJECTED TO FREEZING OR EXCESSIVE HEAT. NO METER SHALL BE LOCATED IN A CRAWL SPACE, UNDER TRAILERS, WELL PITS OR OTHER UNHEATED AREA.
- METER SHALL NOT BE LOCATED IN CABINETS, CLOSETS OR OTHER SUCH LOCATIONS WHICH PREVENT READY ACCESS.
- WHERE PIPING IS NOT RIGID ENOUGH TO SUPPORT METER, MECHANICAL SUPPORTS MUST BE USED.
- WHERE METER IS TO BE INSTALLED ON A WELL TO METER FOR SEWER USAGE, WELL PLASTIC CAN BE USED.
- MUST HAVE (COPPER) FEMALE I.P. ADAPTER BEFORE & AFTER METER SET. IF USING HDPE BEFORE METER AND PLASTIC OR PEX AFTER METER, A MIN. OF 12" OF COPPER PIPE ON BOTH SIDES OF METER.