

City Utilities Design Standards Manual


SADDLE CONNECTION

Revised: January 25, 2017

Created: January 1, 2002

Scale: N.T.S.

Pipes 15" and Larger



Saddle Installation

- 1. Place Saddle on Pipe in the Desired Location. Draw the Hole Size by Placing Marking Pencil Inside the Branch Opening and Marking Pipe.
- 2. Cut 1/4" Outside the Line. Remove Coupon from Inside of Pipe. Scrape any Burrs that Appear Around the Hole.
- 3. Place Saddle on Pipe to Assure that the Pipe Opening is Large Enough to Prevent Obstruction. Enlarge Hole as Necessary.